

**TOWN OF MASHPEE
BOARD OF HEALTH**

SEPTIC INSPECTION POLICY

ALL septic system installations shall now be inspected by an agent of the Board of Health as well as the designing engineer or assigned agent.

Failure to contact the Board of Health for the final inspection of each new, upgrade or repair of the soil absorption system will result in fines and the following:

1. All soil absorption system components shall be exposed for the inspection.
2. The certificate of compliance shall be withheld until the final inspection is performed.
3. A representative of the installer's company shall be present during the inspection.
4. "As-Built" cards shall be completed by the time of the inspection. A sketch shall be provided on the reverse side of the "As Built" card.

All installations must be made in strict conformance with Title V requirements. The following Title V regulations shall be strictly enforced for installations.

1. Risers to within 6" of grade for all septic tanks, distribution boxes and chambers.
2. Inspection ports shall be 6" to grade for infiltrator systems.
3. Clean stone, no fines.
4. H-20 components required within 10' of areas subject to vehicle loading.
5. Carbon filters on all vents. (Recommended)

Steven R. Ball, Chairman
MaryRose Grady, Co-Chairman
L. Glenn Santos, Clerk